

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50500672

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.Z.

Unser Zeichen *Our Reference*
01-SYF-50082664 013

Ausstellungsdatum
22.07.2021

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*
LEADER TECHNOLOGY (SHENZHEN)
CO., LIMITED
FLAT/RM 1402B 14/F THE BELGIAN BANK
NOS.721-725 NATHAN ROAD MONGKOK.KL
Hong Kong

Fertigungsstätte *Manufacturing Plant*
040-0002086538

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
IEC 62930:2017

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable (Cables for Photovoltaic Systems)

Type Designation : 62930 IEC 131 1X2,5...35mm²
HALOGEN FREE LOW SMOKE
LEADER

11

Rated Voltage : DC 1,5kV
AC 1,0/1,0kV

Ambient Temperature : -40°C to +90°C

Max. Temperature
at Conductor : 120°C

11

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety



Kenny Shi

LEADER TECHNOLOGY (SHENZHEN)
CO., LIMITED
Lily Zou

Date : 22.07.2021
Our ref. : SYF 01
Your ref.: L.Z.

FLAT/RM 1402B 14/F THE BELGIAN BANK
BUILDING
NOS.721-725 NATHAN ROAD MONGKOK.KL
Hong Kong

Ref : R TÜV-Mark Approval

Type of Equipment : Cables for Photovoltaic Systems
Model Designation : See Certificate
Certificate No. : R 50500672 0001
Report No. : 50082664 013

Dear Lily Zou,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Kenny Shi

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询